

TEST REPORT

TEST RESULTS

Test Name	Test Method	Specification	Result	Units	Uncertainty of Measurement
Density @ 20 degC	ASTM D4052 **	Report	811.2	Kg/m ³	0.16
Ash Content	ASTM D482 **	Report	0.001	%	
Flashpoint	ASTM D93a **	Report	< 37	deg.C	
Water Content	ASTM D6304 **	Report	1121.5	mg/kg	
Sulphur	ASTM D5453 **	Report	61	mg/kg	1.0
Viscosity @ 40 degC	ASTM D7042 **	Report	2.0	cSt	0.0907
Gross Calorific Value	ASTM D240 **	Report	42.68	MJ/Kg	
Total Sediment	ASTM D4870 **	Report	0	%	